

BID ADDENDUM NO. 1

August 16, 2021

Various Infrastructure Supplies Bid Number 9070-083021-1

Change #1:

Remove Lines 160 and 161 that were listed in Bid Submissions Work Sheets - Schedule 9.

Items Removed

Line Item	Part Description	City Part ID	Unit	Bid Price
160.	1 1/2" MCDONALD BY PASS ASSEMBLY	WD3302	EACH	Removed Per Addendum 1 08/16/21
161.	2" MCDONALD METER BYPASS (36" LONG)	WD3303	EACH	Removed Per Addendum 1 08/16/21

Change #2:

Add Schedule 20 – 1 $\frac{1}{2}$ " and 2" No-Rise Meter Setter Bypass to Bid Submissions Work Sheets. Add Lines 322 and 323

Items Added

Line Item	Part Description		City Part ID	Unit	Bid Price	
	Schedule 20	1 1/2" and 2" No-Rise Meter Setter Bypass				
322.	1 ½" NO-RISE METER SETTER BYPASS		WD3302	EACH		
323.	2" NO-RISE METER S	ETTER BYPASS	WD3303	EACH		

Change #3:

Add Schedule 20 Material Specifications:

Inlet and Outlet Ball Valve

No Rise

Female Iron Pipe Thread on Inlet and Outlet for Service Line

No Lead Alloy

Lay-Length Spacing for 1 1/2" Sensus Omni Compound C2 Meter and 2" Sensus Omni Compound C2 Meter

AY McDonald 720R600WWFF 666 and 720R700WWFF 777 or equals

Ford Meter Box VBB76-00B-11-66-NL and VBB77-00B-11-77-NL or equals

Any Substitutions will have to be approved by the City of Tuscaloosa

Continued onto next page



ACCOUNTING & FINANCE

2201 University Blvd. • Tuscaloosa, AL 35401 • Phone 205-248-5170 • Fax 205-349-0197 • City Hall 205-248-5311

TUSCALOOSA.COM





BID ADDENDUM NO. 1 August 16, 2021

Various Infrastructure Supplies Bid Number 9070-083021-1

Page 2

All Bidders must sign this addendum and return it with their bid submission in order for their bid to be considered.

Additionally, All Bidders who intend to submit a bid for Schedule 20 must enter the amount on Page 1 of this bid addendum.

Company:	
Signature:	

If you have any questions, please contact Amanda Gann at (205) 248-5173	or agann@tuscaloosa.com.
Thank you,	
al A	
Amanda Gann	



Purchasing Agent